PART 0 A/E INSTRUCTIONS

0.01 GENERAL DESIGN REQUIREMENTS

A. Architect shall determine with the DPS Project Manager where slip resistant flooring may be required.

B. Seamless flooring shall not be used in any location without the written approval of the DPS Project Manager.

C. Architect shall not use this product in kitchens, shower rooms, or locker rooms.

D. Architect shall minimize complex patterns requiring acute angles and curves.

E. Architect shall verify with the DPS Project Manager the locations of seamless flooring.

F. Architect shall consult with the DPS Project Manager where flooring may be exposed to chemicals.

G. Architect shall use manufacturer's standard colors unless otherwise approved by the DPS project manager.

H. Architect shall coordinate concrete curing and installation environmental conditions to assure sound installation. Requirements shall be included in this specification section.

PART 1 GENERAL

1.01 QUALITY ASSURANCE

A. Provide all seamless flooring and accessories from a single souce .

B. Applicator must have three years experience, and a minimum of ten installations of this product.

C. Passes ASTMG-21 for resistance to fungi growth, and a minimum of .07 grams loss on the ASTM D-4060 abrasion resistance test.

1.02 SUBMITTALS

A. Installation Instructions and product data.

B. Samples of each face materials, texture, color and accessory to be utilized.

C. Applicator's experience statement.

D. O & M Information.

PART 2 PRODUCTS

2.01 ACCEPTABLE MANUFACTURERS:

A. Provide Seamless flooring as manufactured by the following:

1. Selby Ucrete

2.02 MATERIALS

A. Decorative Quartz or Neutral Silica Broadcast from standard available colors.

B. Polyurethane-cementitious flooring and cove base

1. Minimum 3/16" thick
2. Cove base 6" high with a 1" radius. All cove bases shall terminate into a ¼" deep by ¼" wide saw-cut into the wall at masonry wall terminations and shall terminate at an accessory trim strip at all other locations.

PART 3 EXECUTION

3.01 INSTALLATION

A. Must be closed to traffic for 24 hrs.

B. Provide environmental conditions as recommended by the manufacturer during installation.

3.02 ADDITIONAL MATERIALS

A. Provide a minimum of 1 gallon for each type and color of flooring mix used.

END OF SECTION 09670